

ADDENDUM NO. 1

ROCK RIVER WATER RECLAMATION DISTRICT EMERGENCY POWER DISTRIBUTION UPGRADES GRACEFFA ADMINISTRATION BUILDING CAPITAL PROJECT NO. 1929

This Addendum Number 1, dated October 11, 2018 for the above referenced project, supersedes all contrary and conflicting information in the specifications and contract documents, which are hereby supplemented or revised as follows:


PROJECT SPECIFICATIONS

1. **Article 3, Part 2.5.2.1.A:** Replace text with the following: "Exposed conduit shall be rigidly supported by galvanized hardware and framing materials, including nuts and bolts."
2. **Article 3, Part 2.6:** Add the following to the list of required submittals:
 - a. Contractor shall submit a project safety plan for District record. Work on live electrical panels and/or equipment shall be specifically addressed in the safety plan. The safety plan shall comply with and reference applicable sections of the National Electric Code, National Electrical Safety Code, and National Fire Protection Association.

This information shall be taken into consideration when preparing your bid. This addendum will be E-mailed to all plan holders as well as posted to the District's website at www.rwrwd.dst.il.us.

END OF ADDENDUM NO. 1

Issued October 11, 2018
Rock River Water Reclamation District



Matthew L. Campbell, P.E.
Project Engineer



Christopher T. Baer, P.E.
Engineering Manager