

**ROCK RIVER WATER RECLAMATION DISTRICT
ADDENDUM NO. 2
TO THE INVITATION TO BID #19-211
DIGESTER CLEANING & HAULING OF DEBRIS**

April 10, 2019

AD2-1 Notice

This Addendum No. 2, dated April 10, 2019, to the Invitation to Bid: Digester Cleaning & Hauling of Debris, supersedes all contrary and conflicting information in the above-mentioned instructions, specifications, and contract documents which are hereby supplemented or revised in certain particulars as follows:

AD2-2 General Information

The District submits this Addendum to provide changes and/or additions to Section III, Detailed Specifications, and Section IV, Bid Form.

AD2-3 Instructions to Bidders

1. Add to 3.1 Purpose:

The digester has been in operation for 19 years; it has never been cleaned. Bar screens have had very poor efficiency for the past 5 years.

2. Strike 3.2.A and replace with:

A. Digester Cleaning

The contractor shall furnish all equipment, including safety equipment, pumps, hoses, lights, fans, ladders and hand tools necessary to safely complete this project. Appropriate confined space entry procedures shall be followed while performing this work. Final digester cleaning must at a minimum consist of total removal and disposal of all foreign material (sludge, grit, plastic, trash), and shall consist of flushing the underside cover, walls, piping, and floor. Contractor shall remove debris from the digester, dewater the debris, and transport it to the District's contracted landfill.

3. Strike 3.2.B and replace with:

B. Resources Provided by the District

The District will provide a 1-1/2" water supply at 70 PSI, and 100 amp, 480V, 3 phase power supply

4. Strike 3.2.C and replace with:

C. Dewatering and Hauling of Debris

The contractor shall utilize a dewatering press before hauling debris. Material must be dry enough to pass a paint filter test. Once debris is dewatered, the contractor shall load it onto trucks and haul it to the landfill.

5. Strike 3.2.D and replace with:

D. Deadline for Completion

The Digester Cleaning project shall be completed on or before July 31, 2019.

6. Add to 3.2:

G. Permission from the Landfill

The District will have obtained permission from the landfill to accept digester debris before work begins.

H. Work Hours

Contractor may work 12 hours per day, 7 a.m. – 7 p.m., five days per week, Monday through Friday. No work may be performed on a national holiday.

7. Section IV Bid Form: strike “Price per cubic yard of debris delivered to Advanced Disposal Landfill” and replace with “Price per ton delivered to Advanced Disposal Landfill”.

8. Use revised Section IV Bid Form (page 13 from bid document) attached.

Bidder shall include with his bid a copy of this addendum initialed at the bottom as acknowledgment of receipt.

_____Bidder's Initials

* * * * *

**BID PRICE FOR DIGESTER CLEANING & HAULING of DEBRIS
AS SPECIFIED IN THIS INVITATION TO BID**

All bids shall be the total amount of the bidder's charge, inclusive of labor, equipment, materials, and any and all other expenses necessary to provide Digester Cleaning & Hauling of Debris in complete conformity with any and all provisions of this document. Price shall be expressed in figures.

Price per ton of debris delivered to Advanced Disposal Landfill \$_____

* * * * *

The undersigned acknowledges that he has received Addendum numbers _____,
_____, _____, and realizes that all Addenda are considered part of the Contract.

Date: _____

Respondent:

By:

Print Name of Firm

Authorized Rep's Signature

Print Street Address

Print Rep's Name

Print City, State, Zip

Print Rep's Title

Area Code and Phone Number

Facsimile Number

NOTE: The Rock River Water Reclamation District, a Governmental Unit, pays neither Federal Excise Tax nor Illinois Retailers' Occupational Tax. The bidder shall exclude those taxes from his bid.