Addendum No. 2

Four Rivers Sanitation Authority

Lab Building HVAC Upgrades, Capital Project No. 2202

This Addendum Number 2, dated December 5, 2023, for the above referenced project, supersedes all contrary and conflicting information in the specifications and contract documents, which are hereby supplemented or revised as follows:

GENERAL INFORMATION

The basis of design for the boiler system is 40% ethylene-glycol.

FRSA will not allow hot work / braising inside the Lab Building.

PROJECT MANUAL

Section 23 23 00: Paragraph 2.2-H:

- Add 1. Manufacturers: Subject to compliance with requirements and FRSA approval, provide products by one of the following:
 - a. ZoomLock fittings
 - b. Approved equivalent

This information shall be taken into consideration when preparing your bid. Bidders shall acknowledge all project addenda. This addendum will be emailed to all plan holders as well as posted to FRSA's website at <u>fourrivers.illinois.gov</u>.

End of Addendum No. 2

Issued December 5, 2023

Four Rivers Sanitation Authority

Christopher T. Baer, PE Director of Engineering

I:\District Projects\HVAC Upgrades Lab Building 2202\04 Bidding\Addenda\2 dated 20231205\20231205 Addendum 2.docx