

Addendum No. 1
Four Rivers Sanitation Authority
Co-Generation Efficiency Rehab Project –
Bid Package 1 Electrical Improvements
Capital Project No. 2344

This Addendum Number 1, dated April 2, 2026, for the above referenced project, supersedes all contrary and conflicting information in the specifications and contract documents, which are hereby supplemented or revised as follows:

GENERAL INFORMATION

Agenda of the Mandatory Pre-bid Meeting held on April 1, 2026, is attached to this addendum.

Discussion outside of agenda topics noted on the attached agenda and below:

1. Question: Does this project require Build America Buy America (BABA) compliance?

Answer: No, FRSA is funding this project.

This information shall be taken into consideration when preparing your bid. Bidders shall acknowledge all project addenda. This addendum will be emailed to all plan holders as well as posted to FRSA's website at fourrivers.illinois.gov.

End of Addendum No. 1

Issued April 2, 2026

Four Rivers Sanitation Authority



Matthew L. Campbell, PE
Director of Engineering

I:\District Projects\Cogeneration Efficiency Rehab 2344\04 Bidding\Addenda\01\Addendum 01.docx



Co-Generation Efficiency Rehab Project – Bid Package 1 Electrical Improvements (Capital Project No. 2344)

Pre-Bid Meeting

April 1, 2026

9:00 AM

AGENDA

1. Co-Generation Efficiency Rehab Project – Bid Package 1 Electrical Improvements, Capital Project No. 2344 is comprised of all labor, materials, equipment, and supervision required to construct the following items:
 - a. Replacement of medium voltage feeders F-2 and F-7 which consists of, but is not limited to:
 - 1) Modifications to medium voltage Main Switchgear
 - 2) Replacement of underground medium voltage conductors
 - 3) Two medium voltage pad-mounted switchgear
 - 4) One medium voltage metal-enclosed switchgear
 - 5) Four medium voltage transformers
 - 6) Underground duct banks and manholes
 - 7) Site work, roadway modifications
2. Bid Closing: Bids will be received by Four Rivers Sanitation Authority at 3501 Kishwaukee St., Rockford IL 61109 until 9:00 A.M., Wednesday, **April 15, 2026**. Any Bid received after the time and date specified shall not be considered.
3. Bid must be submitted in a sealed envelope addressed to the Engineering Department at Four Rivers Sanitation Authority at 3501 Kishwaukee Street, Rockford, IL 61109.
4. Mark the outside of the Bid envelope with the following information:
 - a. "BID for Co-Generation Efficiency Rehab Project – Bid Package 1 Electrical Improvements, Capital Project No. 2344"
 - b. Name of bidder
 - c. Bidder address
 - d. Bidder license number, if applicable
 - e. Name of Project

If forwarded by mail, the sealed envelope containing the BID must be enclosed in another envelope addressed to Four Rivers Sanitation Authority, Engineering Department, 3501 Kishwaukee Street, Rockford IL 61109.

5. Instructions to Bidders: This is a lump sum bid project and therefore, there is no electronic proposal form for distribution to potential bidders.
6. Prepare Bid Form by using the Bid Form in the *Bidding Requirements and Contract Forms, General Provisions and Technical Specifications* (Project Manual). All blank spaces for BID prices must be filled in, in ink or typewritten, and the Bid Form must be fully completed and executed when submitted. Only one (1) copy of the Bid Form is required.
7. Submit Bid Form and Bid Bond. Bid Bond not less than 5% of Lump Sum Bid Price.
8. No Bidder may withdraw a Bid within sixty (60) days after the scheduled closing time for receipt of bids.
9. Addenda and Interpretations:
 - a. Last day for questions – Wednesday, April 8, 2026.
 - b. Final addendum issued – Friday April 10, 2026.
10. Refer to Article 2 - Instructions to Bidders for detailed instructions on the preparation and submittal of Bid and other bidding matters.
 - 3.5 Proposal
 - 3.6 Bid Security
 - 3.7 Affidavits
 - A. Fair Employment Practices Affidavit of Compliance
 - B. Affidavit of Compliance: Responsible Bidder Ordinance
 - 3.8 Statement of Qualifications
11. In Bid Form:
 - a. Acknowledge receipt of addendums.
 - b. Fill in the blank for the lump sum bid price.
 - c. Provide Bid Bond in the form of the Bid Bond included in the Bidding Documents.
 - d. Execute the Bid. Properly sign the Bid based on your entity.
 - e. Include completed Base Bid Material and Equipment Schedule
12. Contractors shall be required to pay not less than the prevailing wage rates on the projects as established by the wage rates issued for the project and included in the Wage Rate section of the bidding document.
13. Bidders to review, plan for, and budget the construction sequencing limitations identified in Section 01 11 00—Summary of Work and the Drawings. Those of significant importance are as follows:

- a. One medium voltage feeder – Feeder F-2 or Feeder F-7 – must remain in service at all times. Coordinate with Owner when switching between Feeder F-2 and F-7 is required.
- b. Administration Building must remain powered at all times. Owner has an existing 660kW standby diesel generator located at the Administration Building. The standby generator provides backup power to the Administration Building. Contractor may use Owner's generator to provide temporary power to the Administration Building during times when an outage is required to work on the admin feeder. Contractor is responsible for providing all necessary cost and labor for the operation, maintenance, and servicing of the generator including fueling and refueling.
 - (1) Contractor shall provide an additional temporary standby diesel generator capable of providing a minimum of 660kW. The generator shall provide standby power to the Administration Building should the Owner's generator fail.
- c. A portion of the work will require removing one of two utility power sources to the Dewatering Building. Contractor shall provide a temporary standby diesel generator capable of providing a minimum of 800kW during periods of work when SWB-1 and SWB-2 are single-ended to only one utility power source.
- d. Owner has an existing 3MW Co-Generation system located at the Co-Generation Facility. The Co-Generation system provides continuous power to the Plant via Feeder F-2 or Feeder F-7. The Co-Generation system must remain in service at all times except during the replacement of Feeder F-7C as stated in the possible sequence of construction. The maximum duration the Co-Generation system shall be out of service during this work is 3 days.

14. Project substantial completion: 540 Days

15. All verbal comments made today are to be used at Contractors discretion. Only written documentation in the form of addenda will be binding.

16. Questions

- 1. Does this project require Build America Buy America (BABA) compliance?
Answer: No, FRSA is funding this project.

17. Site Tour

18. Adjourn

